


# CSIR-INSTITUTE OF MINERALS & MATERIALS TECHNOLOGY.

(A Govt. of India Autonomous Body)

Environmental Chemical Laboratory

Bhubaneswar, Odisha



## TEST REPORT

TEST REPORT NO-NABL/ECL/0307/A / NISER

Sl No	Characteristics	Test Method (P) of IS:3025	Requirements as per IS 10500:2012(Latest Version)		Test Result
			Acceptable limit	Permissible Limit	
1.	*Color, Hazen units	Part 4	5	15	<5
2.	*Odour	Part 5	Agreeable	Agreeable	Agreeable
3.	Turbidity, NTU	Part 10	1	5	0.05
4.	pH@Temp ° C	Part 11	6.5-8.5	No relaxation	6.70@25.0
5.	*Conductivity, µs/cm	Part 14	-	-	64
6.	*Total Suspended Solid, mg/l	Part 17	-	-	0.4
7.	Total Dissolved Solids mg/L	Part 16	500	2000	63.0
8.	Total Hardness (as CaCO <sub>3</sub> ),mg/L	Part 21	200	600	17.73
9.	Calcium as Ca, mg/L	Part 40	75	200	3.55
10.	Magnesium as Mg, mg/L	Part 46	30	100	2.15
11.	Alkalinity as CaCO <sub>3</sub> , mg/L	Part 23	200	600	7.94
12.	Chloride as Cl, mg/L	Part 32	250	1000	6.86
13.	Sulfate as SO <sub>4</sub> , mg/L	Part 24	200	400	0.95
14.	Fluoride as F, mg/L	Part 60	1.0	1.5	0.03
15.	*Nitrite as NO <sub>2</sub> ,mg/L	Part 34	-	-	0.0145
16.	*Nitrate as NO <sub>3</sub> , mg/L	Part 34	45	No relaxation	1.274
17.	*Residual free chlorine, mg/L	Part 26	0.02	1.0	BDL
18.	Sodium, mg/l	Part 45	-	-	3.69
19.	Potassium,mg/l	Part 45	-	-	1.89
20.	Dissolved Oxygen, mg/l	Part 38	-	-	7.20
21.	Biological Oxygen Demand, mg/l	Part 44	-	-	0.2
22.	Chemical Oxygen Demand, mg/l	Part 58	-	-	4.0
23.	Free CO <sub>2</sub> , mg/l	Part 60	-	-	14.0

1 of 2

अधीक्षक/Dr. Lakshita Majhi  
प्रधान वैज्ञानिक/Principal Scientist  
पर्यावरण एवं सम्पत्ति विभाग

Environmental & Property Dept.

सोएम्माईआर-खनिज एवं पदार्थ प्रौद्योगिकी संस्थान

CSIR Institute of Minerals & Materials Technology

भुवनेश्वर/Bhubaneswar 751013

Bhubaneswar, Odisha-751013. Tel: 0674-2379236, Mobile: 9760387460.


E-Mail: [dir@immt.res.in](mailto:dir@immt.res.in).

# CSIR-INSTITUTE OF MINERALS & MATERIALS TECHNOLOGY.

(A Govt. of India Autonomous Body)

Environmental Chemical Laboratory

Bhubaneswar, Odisha



## TEST REPORT

24.	Iron as Fe, mg/L	Part 53	0.3	No relaxation	0.160
25.	Copper as Cu, mg/L	Part 42	0.05	1.5	<0.001
26.	Manganese as Mn, mg/L	Part 59	0.1	0.3	0.024
27.	Zinc as Zn, mg/L	Part 49	5.0	15.0	0.402
28.	Lead as Pb, mg/L	Part 47	0.01	No relaxation	<0.001
29.	Cadmium as Cd, mg/L	Part 41	0.003	No relaxation	<0.001
30.	Chromium as Cr, mg/L	Part 52	0.05	No relaxation	0.009
31.	Nickel as Ni, mg/l	Part 54	0.02	No relaxation	<0.001
32.	Oil and Grease, mg/l	Part 39	0.5	No relaxation	BDL

### ➤ BDL- BELOW DETECTION LIMITS

#### NOTES :

1. The sample is drawn by the customer & result relates to the sample tested.
2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
4. Latest version of test methods used as per latest specification.
5. Testing parameters which are not in NABL Scope has marked as "\*" .
6. Testing parameters which are not set limitation has marked as " - " .

Authorized Signatory

**Dr Arakshita Majhi**  
Principal Scientist

Phone : 0674-2379236

E mail - arakshita@immt.res.in

डॉ अराक्षिता माझी/Dr Arakshita Majhi  
प्रधान वैज्ञानिक/Principal Scientist  
पर्यावरण एवं सततता विभाग  
Environmental & Sustainability Dept.  
सीएसआईआर-खनिज एवं पदार्थ प्रौद्योगिकी संस्थान  
CSIR Institute of Minerals & Materials Technology  
भुवनेश्वर/Bhubaneswar 751013