



CSIR-INSTITUTE OF MINERALS & MATERIALS TECHNOLOGY.

(A Govt. of India Autonomous Body)
Environmental Chemical Laboratory
Bhubaneswar, Odisha
TEST REPORT



Issued to : Customer name to be decoded	Date :28.04.2023
Test report No -23/NABL/ECL/03150	
Source of Sample : Source to be decoded	Sample receiving Date : 29.03.2023
Type of Sample : Drinking water	Sample Analysis Date : 29.03.2023

Sl No	Characteristics	Test Method (P)of IS:3025	Requirements as per IS 10500:2012(Latest Version)		Test Result
			Acceptable limit	Permissible Limit	
1.	Turbidity, NTU	Part 10	1	5	0.05
2.	pH@Temp° C	Part 11	6.5-8.5	No relaxation	6.52@25.0
3.	Total Dissolved Solids mg/L	Part 16	500	2000	89.0
4.	Total Hardness (as CaCO ₃),mg/L	Part 21	200	600	28.0
5.	Calcium as Ca, mg/L	Part 40	75	200	8.01
6.	Magnesium as Mg, mg/L	Part 46	30	100	3.89
7.	Alkalinity as CaCO ₃ , mg/L	Part 23	200	600	20.0
8.	Chloride as Cl, mg/L	Part 32	250	1000	21.0
9.	Sulfate as SO ₄ , mg/L	Part 24	200	400	1.37
10.	Fluoride as F, mg/L	Part 60	1.0	1.5	0.07
11.	Iron as Fe, mg/L	Part 53	0.3	No relaxation	0.286
12.	Copper as Cu, mg/L	Part 42	0.05	1.5	0.006
13.	Manganese as Mn, mg/L	APHA(PART 3111B)	0.1	0.3	<0.001
14.	Zinc as Zn, mg/L	Part 49	5.0	15.0	0.011
15.	Lead as Pb, mg/L	Part 47	0.01	No relaxation	<0.001
16.	Cadmium as Cd, mg/L	Part 41	0.003	No relaxation	<0.001
17.	Chromium as Cr, mg/L	Part 52	0.05	No relaxation	<0.001
18.	Nickel as Ni, mg/l	Part 54	0.02	No relaxation	<0.001

Authorized Signatory

Dr. Arakshita Majhi
Principal Scientist

Phone : 0674-2379236,

E mail - arakshita@immt.res.in

डॉ. अरक्षिता माझि/Dr. Arakshita Majhi
प्रधान वैज्ञानिक/Principal Scientist
पर्यावरण एवं सततता विभाग
Environment & Sustainability Dept.
सीएसआईआर-खनिज एवं पदार्थ प्रौद्योगिकी संस्थान
CSIR-Institute of Minerals & Materials Technology
भुवनेश्वर/Bhubaneswar-751013

NOTES :

1. The sample is drawn by the client& result relates to the sample tested.
2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
4. Latest version of test methods used as per latest specification.
5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.

Non NABL Test report – P.T.O

'End of Test Report'



CSIR-INSTITUTE OF MINERALS & MATERIALS TECHNOLOGY.

(A Govt. of India Autonomous Body)
Environmental Chemical Laboratory
Bhubaneswar, Odisha
TEST REPORT

Issued to : Customer name to be decoded			Date :28.04.2023		
Test report No –23/NABL/ECL/03150					
Source of Sample : Source to be decoded			Sample receiving Date : 29.03.2023		
Type of Sample : Drinking water			Sample Analysis Date : 29.03.2023		
19.	*Color, Hazen units	Part 4	5	15	<5
20.	*Odour	Part 5	Agreeable	Agreeable	Agreeable
21.	*Conductivity, $\mu\text{s/cm}$	Part 14	-	-	127
22.	*Total Suspended Solid, mg/l	Part 17	-	-	0.2
23.	*Nitrite as NO_2 ,mg/L	Part 34	-	-	0.245
24.	*Nitrate as NO_3 , mg/L	Part 34	45	No relaxation	2.458
25.	Sodium, mg/l	Part 45	-	-	15.46
26.	Potassium, mg/l	Part 45	-	-	0.98
27.	Residual Free Chlorine, mg/l	Part 26	0.2	1.0	<0.1
28.	Arsenic as As, mg/l	Part 37	0.01	No relaxation	<0.001
29.	Dissolved Oxygen, mg/l	Part 38	-	-	6.20
30.	Biological Oxygen Demand, mg/l	Part 44	-	-	BDL
31.	Chemical Oxygen Demand, mg/l	Part 58	-	-	BDL
32.	Oil and Grease, mg/l	Part 39	0.5	No relaxation	<0.1

BDL – Below Detection Limit

Authorized Signatory

Dr. Arakshita Majhi

Principal Scientist

Phone : 0674-2379236,

E mail - arakshita@immt.res.in

डॉ. अरक्षिता माझि/Dr. Arakshita Majhi

प्रधान वैज्ञानिक/Principal Scientist

पर्यावरण एवं सम्पोधन विभाग

Environment & Sustainability Dept.

सीएसआईआर-खनिज एवं पदार्थ प्रौद्योगिकी संस्थान

CSIR-Institute of Minerals & Materials Technology

भुवनेश्वर/Bhubaneswar-751013

NOTES :

1. The sample is drawn by the client& result relates to the sample tested.
2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of laboratory.
4. Latest version of test methods used as per latest specification.
5. It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned in "acceptable limit" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicate under "permissible limit" in the absence of alternative sources, above which the source will have to be rejected.
6. Testing parameters which are not set limitation has marked as "-".

'End of Test Report'




Test Report

Sample code: <u>NABL/EBL04150</u>	Test report Date: 09.5.2023
Test Report No.: <u>ULR- TC819521000000000144/EBL5/23-4</u>	
Source of Sample (provided by the customer): Water works	Sample condition: Satisfactory
Date of Sampling (provided by the customer): 29.03.2023	Sample Received on: 29.03.2023
Type of Sample: Potable water	Sample analysis started on: 01.4.2023

Sl. No.	Test/Parameter	Test Method	Requirements as per IS 10500:2012 (RA 2018)		Test Result with units of measurement	Statement of Conformity
			Acceptable limit	Permissible Limit		
1.	<i>E.coli</i> by Membrane filtration	IS 15185 RA 2018	Shall not be detect in 100ml sample	No relaxation	Absent 100 ml	Conformance
2.	Total coliform by MPN	IS 1622 RA 2019	Shall not be detect in 100ml sample	No relaxation	<2 MPN/100mL	Conformance
3.	Fecal coliform by MPN	IS 1622 RA 2019	Shall not be detect in 100ml sample	No relaxation	<2 MPN/100 mL	Conformance

End of test report

Authorized Signatory


9.5.23
Quality Manager
Dr. Sony Pandey
(Principal Scientist, E&S Department)

Environmental Biology Lab
Lab, E&S Dept.

Notes:

1. The test report relates only to the items tested.
2. The sample is drawn by the customer, hence EBL is not responsible for any errors arising out of faulty sample withdrawal, handling or container.
3. Sterile containers and aseptic handling of samples during collection and transport is necessary for correct results. EBL is not responsible for mistakes on the part of customers.
4. The decision rule is inherent in the standard as the acceptable and permissible limits are pre-defined.

Contact: Head, Environment & Sustainability Department at Tel: 91-674-2379411/2379271/2379242. Mobile: 9437460626/9437290470/9337733311, email: head.es@immt.res.in, Website: www.immt.res.in

ULR-TC819521000000000144/EBL5/23-4

Doc No. QR26

Page 2 of 3