

Tender No. NIT-01/2019-NC-001148-PHY-18-19 (revised)

Company Name	Remarks
Benzfab Technologies Pvt. Ltd	Bid accepted
Netweb Technologies India Pvt. Ltd	Bid accepted
Micropoint Computers Pvt. Ltd.	Bid Rejected 1. UPS output power factor is 0.9 but as per tender it should be unity 2. In-build isolation transformer is asked as per the tender, But the provided model (APC Online 6kVA UPS Model-SRC6KUXI) does not have the same.
Netcom Infotech Pvt. Ltd	Bid accepted

K Saha
03/09/2019

Dr. Kush Saha