

To FIC Purchase,

NISER

Evaluation of technical bids NC-001253-001348-CHE-18-19

Following three suppliers participated.

1. HYGRO TECH ENGINEERS
2. NABARUPAYAN
3. KAF INTERNATIONAL

Among the above three suppliers, KAF INTERNATIONAL is disqualified in following grounds

1. This model is a portable dehumidifier, not suitable for laser lab. Due to small size of the laser room, we prefer to keep our dehumidifier outside the room, which is not possible with this model.
2. Water tank capacity is 7 liter, it is too small and we have to vacate the tank in every few hours, which is not possible.

Other two companies (Hygro Techengineers and Nabarupayan) are qualified.

Sincerely,

(Subhadip Ghosh)

Subhadip Ghosh
31/8/2019